

Hazardous Substances (Emergency Management) Amendment Regulations 2004

Pursuant to section 76(1)(d) of the Hazardous Substances and New Organisms Act 1996, Her Excellency the Governor-General, acting on the advice and with the consent of the Executive Council (given on the recommendation of the Minister for the Environment made in compliance with section 141(1) of that Act), makes the following regulations.

Contents

		Page
1	Title	2
2	Commencement	2
3	Interpretation	2
4	New regulation 4A inserted	3
	4A Exclusion for fuel gases	3
5	Content	3
6	Heading to Part 3 amended	4
7	Information duties under Part 3 of suppliers	4
8	Certain suppliers to give further information if asked	4
9	Information duties under Part 3 of persons in charge of places of work	4
10	Alternative information for substances being transported	4
11	Cross-heading amended	5
12	General content	5
13	Extra content for flammable and oxidising substances and organic peroxides	5
14	New regulation 18 substituted	5
	18 Location and presentation of documentation	5
15	Regulation 19 revoked	5
16	Fire extinguishers required	5
17	Capability of fire extinguishers	5

18	Duties of persons in charge of places under this Part	6
19	Extra information required in some cases	6
20	Terms used in regulations 36 to 41	6
21	Secondary containment systems for pooling substances	6
22	New regulation 40 substituted	7
	40 Below ground containers	7
23	New Schedules 1 to 5 substituted	7
	Schedule	7
	New Schedules 1 to 5 substituted in principal regulations	

1 Title

- (1) These regulations are the Hazardous Substances (Emergency Management) Amendment Regulations 2004.
- (2) In these regulations, the Hazardous Substances (Emergency Management) Regulations 2001¹ are called “the principal regulations”.

2 Commencement

These regulations come into force on 26 March 2004.

3 Interpretation

- (1) Regulation 3(1) of the principal regulations is amended by inserting, before the definition of incompatible, the following definitions:

“**aerosol** has the same meaning as in clause 1 of Schedule 2 of the Hazardous Substances (Classification) Regulations 2001

“**Authority** means the Environmental Risk Management Authority established under section 14 of the Hazardous Substances and New Organisms Act 1996

“**documentation** includes information recorded electronically

“**hazard classification** means a classification under the classification system described in regulation 4 of the Hazardous Substances (Classification) Regulations 2001”.

¹ SR 2001/123

- (2) Regulation 3(1) of the principal regulations is amended by omitting from the definition of **incompatible** the words “regulation 84, or regulation 103”, and substituting the words “regulation 87, or regulation 105”.

4 New regulation 4A inserted

The principal regulations are amended by inserting, after regulation 4, the following regulation:

“4A Exclusion for fuel gases

- “(1) The requirements of these regulations do not apply to any fuel gas supplied or used in a gas distribution system, gas appliance, or gas installation, when subject to the Gas Act 1992.

- “(2) In subclause (1),—

“**fuel gas** means any fuel supplied through pipes or in containers that is a gas at 15°C and 101.3 kPa absolute pressure; and includes—

“(a) biogas, coal gas, liquified petroleum gas, natural gas, oil gas, producer gas, refinery gas, and reformed natural gas; and

“(b) any gaseous substance that the Governor-General declares by Order in Council under the Gas Act 1992 to be a gas for the purposes of that Act; and

“(c) any gaseous substance or mixture whose composition complies with regulations under the Gas Act 1992 allowing it to be used as fuel; and

“(d) any mixture of fuel gases

“**gas appliance** has the meaning given to that term by section 2(1) of the Gas Act 1992

“**gas distribution** means a distribution system within the meaning of section 2(1) of the Gas Act 1992

“**gas installation** has the meaning given to that term by section 2(1) of the Gas Act 1992.

- “(3) This regulation overrides all other provisions of these regulations.”

5 Content

Regulation 8(c)(i) and (e)(i) of the principal regulations is revoked.

6 Heading to Part 3 amended

The principal regulations are amended by omitting, from the heading to Part 3, the word “information”, and substituting the word “documentation”.

7 Information duties under Part 3 of suppliers

The heading to regulation 12 of the principal regulations is amended by omitting the word “Information”, and substituting the word “Documentation”.

8 Certain suppliers to give further information if asked

- (1) The heading to regulation 13 of the principal regulations is amended by omitting the word “information”, and substituting the word “documentation”.
- (2) Regulation 13 of the principal regulations is amended by omitting the word “information”, and substituting the word “documentation”.

9 Information duties under Part 3 of persons in charge of places of work

- (1) The heading to regulation 14 of the principal regulations is amended by omitting the word “Information”, and substituting the word “Documentation”.
- (2) Regulation 14(1) of the principal regulations is amended by omitting the expression “3.1D, 5.3G, 6.1E, 6.3A, 6.4A, 9.1D, or 9.2D” wherever it occurs, and substituting in each case the expression “3.1D, 5.2G, 6.1E, 6.3A, 6.3B, 6.4A, 9.1D, or 9.2D”.
- (3) Regulation 14(2) of the principal regulations is amended by omitting the word “information” in both places where it occurs, and substituting in each case the word “documentation”.

10 Alternative information for substances being transported

The heading to regulation 15 of the principal regulations is amended by omitting the word “information”, and substituting the word “documentation”.

- 11 Cross-heading amended**
The cross-heading immediately above regulation 16 of the principal regulations is amended by omitting the word “information”, and substituting the word “documentation”.
- 12 General content**
The heading to regulation 16 of the principal regulations is amended by adding the words “requirements for documentation”.
- 13 Extra content for flammable and oxidising substances and organic peroxides**
The heading to regulation 17 of the principal regulations is amended by omitting the words “Extra content”, and substituting the words “Specific documentation requirements”.
- 14 New regulation 18 substituted**
The principal regulations are amended by revoking regulation 18 and substituting the following regulation:
“**18 Location and presentation of documentation**
Documentation required by regulation 16 or regulation 17 must be provided in accordance with regulation 48 of the Hazardous Substances (Identification) Regulations 2001, and regulation 48 applies with all necessary modifications.”
- 15 Regulation 19 revoked**
Regulation 19 of the principal regulations is revoked.
- 16 Fire extinguishers required**
Regulation 21(3)(a) of the principal regulations is amended by omitting the expression “103 kPa”, and substituting the expression “101.3 kPa”.
- 17 Capability of fire extinguishers**
Regulation 23 of the principal regulations is amended by omitting the expression “6 m”, and substituting the expression “6 m²”.

18 Duties of persons in charge of places under this Part

Regulation 25(3)(b)(i) of the principal regulations is amended by omitting the expression “103 kPa”, and substituting the expression “101.3 kPa”.

19 Extra information required in some cases

Regulation 30(a) of the principal regulations is amended by omitting the words “design and installation”, and substituting the words “type and location”.

20 Terms used in regulations 36 to 41

(1) Regulation 35 of the principal regulations is amended by revoking paragraph (a) of the definition of **pooling substance**, and substituting the following paragraph:

“(a) is a liquid; or”.

(2) Regulation 35 of the principal regulations is amended by revoking the definition of **secondary containment system**, and substituting the following definition:

“**secondary containment system**, in relation to a place,—

“(a) means a system or systems—

“(i) in which pooling substances held in the place will be contained if they escape from the container or containers in which they are being held; and

“(ii) from which they can, subject to unavoidable wastage, be recovered; and

“(b) includes a system or systems that comply with a code of practice approved by the Authority under section 78 of the Hazardous Substances and New Organisms Act 1996”.

21 Secondary containment systems for pooling substances

Regulation 36 of the principal regulations is amended by inserting, after subclause (2), the following subclause:

“(2A) If 2 or more containers of different capacities (as described in regulations 37 to 39) are held at one place, the system must have a capacity of at least the sum of each container category.”

22 New regulation 40 substituted

The principal regulations are amended by revoking regulation 40, and substituting the following regulation:

“40 Below ground containers

“(1) If the pooling substances held in a place are in 1 or more below ground containers, the secondary containment system must have a capacity at least equal to the total pooling potential.

“(2) In subclause (1), **below ground container**—

“(a) means a container that is situated below ground; and

“(b) includes—

“(i) a container below ground, the level of which has been raised to provide cover for the container; and

“(ii) a container covered by other incombustible material instead of ground.”

23 New Schedules 1 to 5 substituted

The principal regulations are amended by revoking Schedules 1 to 5, and substituting the schedules set out in the Schedule of these regulations.

Schedule

r 23

**New Schedules 1 to 5 substituted in
principal regulations**
Schedule 1

rr 6, 7(1)

Quantities requiring Level 1 information

Hazard classification	Description	Quantity
1—all hazard classifications except the following:	gas, liquid, or solid	any quantity

Schedule 1—*continued*

Hazard classification	Description	Quantity
(a) safety ammunition, including pre-primed cartridges and primers, of class 1.4S; and		
(b) airbag initiators and seatbelt pretensioners of classes 1.4G and 1.4S; and		
(c) fireworks subject to the Hazardous Substances (Fireworks) Regulations 2001; and		
(d) cable cutters of class 1.4S (UN 0070); and		
(e) power device cartridges of class 1.4S (UN 0323); and		
(f) signal or shock tubes of class 1.4S (UN 0349); and		

Schedule 1—*continued*

Hazard classification	Description	Quantity
(g) cassette degradation devices of class 1.4S (UN 0432); and		
(h) emergency flares and signalling devices of classes 1.3 G, 1.4G, and 1.4S; and		
(i) model rocket motors of classes 1.4G and 1.4S; and		
(j) igniting fuzes of class 1.4G (UN 0317); and		
(k) igniters of class 1.4S (UN 0454).		
2.1.1A	non-permanent gas	0.2 kg
	permanent gas	0.2 m ³
2.1.1B	non-permanent gas	0.5 kg
	permanent gas	0.5 m ³
2.1.2A	aerosol	1.0 L aggregate water capacity
3.1A	liquid	0.5 L
3.1B, 3.1C	liquid	1.0 L
3.1D	liquid	5.0 L

Schedule 1—*continued*

Hazard classification	Description	Quantity
3.2A, 3.2B, 3.2C	liquid	0.2 L
4.1.1A	solid	0.5 kg
4.1.1B	solid	1.0 kg
4.1.2A, 4.1.2B, 4.1.2C, 4.1.2D, 4.1.2E, 4.1.2F, 4.1.2G	liquid	0.2 L
	solid	0.2 kg
4.1.3A, 4.1.3B, 4.1.3C	liquid	0.2 L
	solid	0.2 kg
4.2A	liquid	0.2 L
	solid	0.2 kg
4.2B	solid	0.5 kg
4.2C	solid	1.0 kg
4.3A	liquid	0.2 L
	solid	0.2 kg
4.3B	liquid	0.5 L
	solid	0.5 kg
4.3C	liquid	1.0 L
	solid	1.0 kg
5.1.1A	liquid	0.2 L
	solid	0.2 kg

Schedule 1—*continued*

Hazard classification	Description	Quantity
5.1.1B	liquid	0.5 L
	solid	0.5 kg
5.1.1C	liquid	1.0 L
	solid	1.0 kg
5.1.2A	non-permanent gas	1.0 kg
	permanent gas	1.0 m ³
5.2A, 5.2B, 5.2C, 5.2D	liquid	0.1 L
	solid	0.1 kg
5.2E, 5.2F	liquid	0.5 L
	solid	0.5 kg
5.2G	liquid	5.0 L
	solid	5.0 kg
6.1A, 6.1B, 6.1C	gas, liquid, or solid	any quantity
6.1D, 6.3A, 6.4A	non-permanent gas	0.1 kg
	permanent gas	0.1 m ³
	liquid	0.1 L
	solid	0.1 kg
6.1E, 6.3B, 6.5A, 6.5B	liquid	1.0 L
	solid	1.0 kg
8.1A, 8.2B	gas, liquid, or solid	any quantity

Schedule 1—*continued*

Hazard classification	Description	Quantity
8.2C, 8.3A	non-permanent gas	0.1 kg
	permanent gas	0.1 m ³
	liquid	0.1 L
	solid	0.1 kg
9.1A, 9.2A, 9.3A, 9.4A	liquid	0.1 L
	solid	0.1 kg
9.1B, 9.2B, 9.3B, 9.4B	liquid	0.2 L
	solid	0.2 kg
9.1C, 9.1D, 9.2C, 9.2D, 9.3C, 9.4C	liquid	1.0 L
	solid	1.0 kg

(All liquid volumes measured at 20°C)

Schedule 2
Quantities requiring Level 2 documentation

rr 12, 14(1)

Hazard classification	Description	Quantity
The following class 1:	gas, liquid, or solid	5 kg (gross weight) per package

Schedule 2—*continued*

Hazard classification	Description	Quantity
(a)	airbag initiators and seatbelt pretensioners of classes 1.4G or 1.4S; and	
(b)	cable cutters of class 1.4S (UN 0070); and	
(c)	power device cartridges of class 1.4S (UN 0323); and	
(d)	signal or shock tubes of class 1.4S(UN 0349); and	
(e)	cassette degradation devices of class 1.4S (UN 0432); and	
(f)	emergency flares and signalling devices of classes 1.3G, 1.4G, and 1.4S; and	
(g)	model rocket motors of class 1.4G and 1.4S; and	

Schedule 2—*continued*

Hazard classification	Description	Quantity
(h) igniting fuzes of class 1.4G (UN 0317); and		
(i) igniters of class 1.4S (UN 0454).		
The rest of class 1 except—	gas, liquid, or solid	any quantity
(a) fireworks subject to the Hazardous Substances (Fireworks) Regulations 2001; and		
(b) safety ammunition, including pre-primed cartridges and primers, of class 1.4S.		
2.1.1A	non-permanent gas	0.2 kg
	permanent gas	0.2 m ³
2.1.1B	non-permanent gas	0.5 kg
	permanent gas	0.5 m ³
2.1.2A	aerosol	1.0 L aggregate water capacity
3.1A	liquid	0.5 L
3.1B	liquid	1.0 L

Schedule 2—*continued*

Hazard classification	Description	Quantity
3.1C	liquid	5.0 L
3.1D	liquid	5.0 L
3.2A, 3.2B, 3.2C	liquid	any quantity
4.1.1A	solid	0.5 kg
4.1.1B	solid	3.0 kg
4.1.2A, 4.1.2B, 4.1.2C, 4.1.2D, 4.1.2E, 4.1.2F, 4.1.2G	liquid or solid	any quantity
4.1.3A, 4.1.3B, 4.1.3C	liquid or solid	any quantity
4.2A	liquid or solid	any quantity
4.2B	solid	0.5 kg
4.2C	solid	3.0 kg
4.3A	liquid or solid	any quantity
4.3B	liquid	0.5 L
	solid	0.5 kg
4.3C	liquid	1.0 L
	solid	1.0 kg
5.1.1A	liquid or solid	any quantity
5.1.1B	liquid	0.5 L
	solid	0.5 kg

Schedule 2—*continued*

Hazard classification	Description	Quantity
5.1.1C	liquid	1.0 L
	solid	1.0 kg
5.1.2A	non-permanent gas	1.0 kg
	permanent gas	1.0 m3
5.2A	liquid or solid	any quantity
5.2B, 5.2C, 5.2D, 5.2E, 5.2F—if substance needs temperature control under the Hazardous Substances (Classes 1 to 5 Controls) Regulations 2001	liquid or solid	any quantity
5.2B, 5.2C—if substance does not need temperature control under the Hazardous Substances (Classes 1 to 5 Controls) Regulations 2001	liquid	25 mL
	solid	0.1 kg

Schedule 2—*continued*

Hazard classification	Description	Quantity
5.2D, 5.2E, 5.2F—if substance does not need temperature control under the Hazardous Substances (Classes 1 to 5 Controls) Regulations 2001	liquid	125 mL
	solid	0.5 kg
5.2G	liquid	50 L
	solid	50 kg
6.1A, 6.1B	gas, liquid, or solid	any quantity
6.1C, 6.6A, 6.7A, 6.8A, 6.9A	non-permanent gas	0.1 kg
	permanent gas	0.1 m ³
	liquid	0.1 L
	solid	0.5 kg
6.1D, 6.5A, 6.5B, 6.6B, 6.7B, 6.8B, 6.8C, 6.9B	non-permanent gas	1.0 kg
	permanent gas	1.0 m ³
	liquid	1.0 L
	solid	3.0 kg
6.1E, 6.3A, 6.3B, 6.4A	liquid	50 L

Schedule 2—*continued*

Hazard classification	Description	Quantity
	solid	50 kg
8.2A	gas, liquid, or solid	any quantity
8.2B	non-permanent gas	0.5 kg
	permanent gas	0.5 m ³
	liquid	0.5 L
	solid	1.0 kg
8.1A, 8.2C, 8.3A	non-permanent gas	1.0 kg
	permanent gas	1.0 m ³
	liquid	1.0 L
	solid	2.0 kg
9.1A, 9.1B, 9.1C, 9.2A, 9.2B, 9.2C, 9.3A, 9.3B, 9.3C, 9.4A, 9.4B, 9.4C	liquid	5.0 L
	solid	5.0 kg
9.1 D, 9.2D	liquid	50 L
	solid	50 kg

(All liquid volumes measured at 20°C)

Schedule 3
Quantities requiring fire extinguishers

r 21(1)

Hazard classification	Description	Quantity	No
1.1A, 1.1B, 1.2B	solid	1 kg	1
1.1C, 1.1D, 1.1E 1.1F, 1.1G, 1.1J, 1.1L, 1.2C, 1.2D, 1.2E, 1.2F, 1.2G, 1.2H, 1.2J, 1.2K, 1.2L, 1.3C, 1.3F, 1.3G, 1.3H, 1.3J, 1.3K, 1.3L	liquid	25 L	1
	solid	25 kg	
1.4B, 1.4C, 1.4D, 1.4E, 1.4F, 1.4G, 1.4S, 1.5D, 1.6N	solid	50 kg	1
Fireworks subject to the Hazardous Substances (Fireworks) Regulations 2001	solid	300 kg (gross weight)	1
Safety ammunition, including pre-primed cartridges and primers, of class 1.4S	solid	500 kg (gross weight)	1
2.1.1A	non-permanent gas	50 kg	1
	permanent gas	30 m3	

Schedule 3—*continued*

Hazard classification	Description	Quantity	No
2.1.1B	non-permanent gas	200 kg	2
	permanent gas	120 m ³	
2.1.2A	aerosol	3 000 L aggregate water capacity	1
3.1A	liquid	50 L	1
		200 L	2
3.1B	liquid	250 L	2
3.1C, 3.1D	liquid	500 L	2
3.2A, 3.2B, 3.2C	liquid	50 L	1
		200 L	2
4.1.1A	solid	250 kg	2
4.1.1B	solid	500 kg	2
4.1.2A, 4.1.2B, 4.1.2C, 4.1.2D, 4.1.2E, 4.1.2F, 4.1.2G	liquid	50 L	1
		200 L	2
	solid	50 kg	1
4.1.3A, 4.1.3B, 4.1.3C	liquid	200 kg	2
		50 L	1
		200 L	2

Schedule 3—*continued*

Hazard classification	Description	Quantity	No
	solid	50 kg	1
		200 kg	2
4.2A	liquid	50 L	1
		200 L	2
	solid	50 kg	1
		200 kg	2
4.2B	solid	250 kg	2
4.2C	solid	500 kg	2
4.3A	liquid	50 L	1
		200 L	2
	solid	50 kg	1
		200 kg	2
4.3B	liquid	250 L	2
	solid	250 kg	
4.3C	liquid	500 L	2
	solid	500 kg	
5.1.1A	liquid	5 L	1
	solid	5 kg	
5.1.1B	liquid	200 L	1
	solid	200 kg	
5.1.1C	liquid	500 L	2

Schedule 3—*continued*

Hazard classification	Description	Quantity	No
	solid	500 kg	
5.1.2A	non-permanent gas	10 kg	1
		50 kg	2
	permanent gas	10 m3	1
		50 m3	2
5.2A, 5.2B	liquid	1 L	1
	solid	1 kg	
5.2C, 5.2D	liquid	10 L	1
	solid	10 kg	
5.2E, 5.2F	liquid	50 L	1
	solid	50 kg	

Schedule 4
Threshold quantities for Level 3

r 25(1)

Hazard classification	Description	Quantity
1.1A, 1.1B, 1.1C, 1.1D, 1.1E, 1.1F, 1.1G, 1.1J, 1.1L, 1.2B, 1.2C, 1.2D, 1.2E, 1.2F, 1.2G, 1.2H, 1.2J 1.2K, 1.2L	liquid	50 L

Schedule 4—*continued*

Hazard classification	Description	Quantity
	solid	50 kg
1.3C, 1.3F, 1.3G, 1.3H, 1.3J, 1.3K, 1.3L	liquid	100 L
	solid	100 kg
1.4B, 1.4C, 1.4D, 1.4E, 1.4F, 1.4G, 1.4S, 1.5D, 1.6N, except the following:	liquid	200 L
	solid	200 kg
(a) fireworks subject to the Hazardous Substances (Fireworks) Regulations 2001: and		
(b) safety ammunition, including pre- primed cartridges and primers, of class 1.4S; and		
(c) airbag initiators and seatbelt pretensioners of classes 1.4G and 1.4S: and		

Schedule 4—*continued*

Hazard classification	Description	Quantity
(d) cable cutters of class 1.4S (UN 0070); and		
(e) power device cartridges of class 1.4S (UN 0323); and		
(f) signal or shock tubes of class 1.4S (UN 0349); and		
(g) cassette degradation devices of class 1.4S (UN 0432); and		
(h) emergency flares and signalling devices of classes 1.3G, 1.4G, and 1.4S,		
2.1.1A	non-permanent gas	300 kg
	permanent gas	200 m ³
2.1.1B	non-permanent gas	1 000 kg
	permanent gas	600 m ³
2.1.2A	aerosol	3 000 L aggregate water capacity
3.1A	liquid	100 L
3.1B	liquid	1 000 L

Schedule 4—*continued*

Hazard classification	Description	Quantity
3.1C, 3.1D	liquid	10 000 L
3.2A, 3.2B, 3.2C	liquid	100 L
4.1.1A	solid	1 000 kg
4.1.1B	solid	10 000 kg
4.1.2A, 4.1.2B	liquid	50 L
	solid	50 kg
4.1.2C, 4.1.2D	liquid	100 L
	solid	100 kg
4.1.2E, 4.1.2F, 4.1.2G	liquid	200 L
	solid	200 kg
4.1.3A, 4.1.3B, 4.1.3C	liquid	100 L
	solid	100 kg
4.2A	liquid	100 L
	solid	100 kg
4.2B	solid	1 000 kg
4.2C	solid	10 000 kg
4.3A	liquid	100 L
	solid	100 kg
4.3B	liquid	1 000 L
	solid	1 000 kg

Schedule 4—*continued*

Hazard classification	Description	Quantity
4.3C	liquid	10 000 L
	solid	10 000 kg
5.1.1A	liquid	50 L
	solid	50 kg
5.1.1B	liquid	500 L
	solid	500 kg
5.1.1C	liquid	5 000 L
	solid	5 000 kg
5.1.2A	non-permanent gas	100 kg
	permanent gas	100 m ³
5.2A, 5.2B	liquid	10 L
	solid	10 kg
5.2C, 5.2D	liquid	25 L
	solid	25 kg
5.2E 5.2F	liquid	100 L
	solid	100 kg
6.1A, 6.1B, 6.1C	non-permanent gas	5 kg
	permanent gas	2.5 m ³
	liquid	100 L
	solid	100 kg

Schedule 4—*continued*

Hazard classification	Description	Quantity
6.1D, 6.5A, 6.5B, 6.7A	non-permanent gas	50 kg
	permanent gas	25 m ³
	liquid	1 000 L
	solid	1 000 kg
6.6A, 6.7B, 6.8A, 6.9A	liquid	10 000 L
	solid	10 000 kg
8.2A	non-permanent gas	5 kg
	permanent gas	2.5 m ³
	liquid	100 L
	solid	100 kg
8.2B	non-permanent gas	50 kg
	permanent gas	25 m ³
	liquid	1 000 L
	solid	1 000 kg
8.2C, 8.3A	liquid	10 000 L
	solid	10 000 kg
9.1A	liquid	100 L
	solid	100 kg
9.1B, 9.1C	liquid	1 000 L
	solid	1 000 kg

Schedule 4—*continued*

Hazard classification	Description	Quantity
9.1D	liquid	10 000 L
	solid	10 000 kg

Schedule 5
Quantities requiring signage

r 42

Hazard classification	Description	Quantity
1	Fireworks subject to the Hazardous Substances (Fireworks) Regulations 2001	1 000 kg (gross weight)
	Safety ammunition, including pre-primed cartridges and primers, of class 1.4S	10 000 kg (gross weight)
	Airbag initiators and seatbelt pretensioners of class 1.4G and 1.4S	5 000 kg (gross weight)
	Cable cutters of class 1.4S (UN 0070)	5 000 kg (gross weight)
	Power device cartridges of class 1.4S (UN 0323)	5 000 kg (gross weight)

Schedule 5—*continued*

Hazard classification	Description	Quantity
	Signal or shock tubes of class 1.4S (UN 0349)	5 000 kg (gross weight)
	Cassette degradation devices of class 1.4S(UN 0432)	5 000 kg (gross weight)
	Propellants of class 1.1C (UN 0160) and 1.3C (UN 0161 and UN 0499), gun-powder of class 1.1D (UN 0027), and substances of classes 1.3G, 1.4G, and 1.4S not listed above	50 kg
	All remaining explosive hazardous classifications	any quantity
2.1.1A	non-permanent gas	250 kg
	permanent gas	100 m3
2.1.1B	non-permanent gas	500 kg
	permanent gas	200 m3
2.1.2A	aerosol	3 000 L aggregate water capacity
3.1A, 3.2A, 4.1.3A, 4.2A, 4.3A	liquid	50 L
	solid	50 kg

Schedule 5—*continued*

Hazard classification	Description	Quantity
3.1B, 3.2B, 4.1.3B, 4.2B, 4.3B	liquid	250 L
	solid	250 kg
3.1C, 3.2C, 4.1.3C, 4.2C, 4.3C	liquid	1 000 L
	solid	1 000 kg
3.1D	liquid	10 000 L
4.1.1A	solid	250 kg
4.1.1B	solid	1 000 kg
4.1.2A, 4.1.2B	liquid	50 L
	solid	50 kg
4.1.2C, 4.1.2D	liquid	250 L
	solid	250 kg
4.1.2E, 4.1.2F, 4.1.2G	liquid	1 000 L
	solid	1 000 kg
5.1.1A	liquid	50 L
	solid	50 kg
5.1.1B	liquid	500 L
	solid	500 kg
5.1.1C	liquid	1 000 L
	solid	1 000 kg

Schedule 5—*continued*

Hazard classification	Description	Quantity
5.1.2A	non-permanent gas	250 kg
	permanent gas	500 m ³
5.2A, 5.2B	liquid	1 L
	solid	1 kg
5.2C, 5.2D, 5.2E, 5.2F	liquid	10 L
	solid	10 kg
6.1A	liquid	50 L
	solid	50 kg
6.1B	liquid	250 L
	solid	250 kg
6.1C	liquid	1 000 L
	solid	1 000 kg
6.1D	liquid	10 000 L
	solid	10 000 kg
6.1A, 6.1B. 6.1C	non-permanent gas	5 kg
	permanent gas	2.5 m ³
8.1A	liquid	1 000 L
	solid	1 000 kg
8.2A	non-permanent gas	5 kg
	permanent gas	2.5 m ³

Schedule 5—*continued*

Hazard classification	Description	Quantity
	liquid	50 L
	solid	50 kg
8.2B	non-permanent gas	50 kg
	permanent gas	25 m ³
	liquid	250 L
	solid	250 kg
8.2C, 8.3A	liquid	1 000 L
	solid	1 000 kg
9.1A, 9.2A, 9.3A, 9.4A	liquid	100 L
	solid	100 kg
9.1B, 9.1C, 9.2B, 9.2C, 9.3B, 9.4B, 9.4C	liquid	1 000 L
	solid	1 000 kg
9.1D, 9.2D, 9.3C	liquid	10 000 L
	solid	10 000 kg

Diane Morcom,
Clerk of the Executive Council.

Explanatory note

This note is not part of the regulations, but is intended to indicate their general effect.

These regulations, which come into force on 26 March 2004, amend the Hazardous Substances (Emergency Management) Regulations 2001—

- to account for the transfer of dangerous goods from current regulatory regimes, or transitional regimes under the Hazardous Substances and New Organisms Act 1996, to permanent control under the Hazardous Substances and New Organisms Act 1996:
- to correct cross-references and minor technical and drafting errors.

Issued under the authority of the Acts and Regulations Publication Act 1989.
Date of notification in *Gazette*: 4 March 2004.
